

# Evaluation of energy supply options for CMU

**Alexander E. Farrell**

**Research Assistants:**

**Dave Lorenzi**

**Tony Paez**

**Carnegie Mellon Electricity Industry Center**



# Introduction

- Distributed generation (DG) in combined heat and power (CHP) applications is a significant fraction of generation in some systems (6% in the Netherlands).
  - Utility companies have incentive to cooperate
  - Policies must allow for flexible ownership and operations
  - Recapture of waste heat crucial to economics
- Thermal demand of U.S. buildings: less heat more cooling
  - Less opportunity for waste heat recapture
- Can absorption cooling be used with DG to create a CHCP system that might be economically advantageous?

# Approach


- CMU energy supply system
  - Electricity bought from grid (60% coal, 38% nuke/hydro, 2% gas)
  - 20% of electricity is wind (5% total energy)
  - Heat from district heating system (85% coal, 15% gas)
- Replacement of district heating system being considered
  - Base system (coal heat and grid electricity with wind purchase)
  - Gas-fired heat and grid electricity (more generalizable)
  - Onsite, gas-fired electricity generation with waste heat recapture
    - Compression chilling (current)
    - Absorption chilling
- Simulation model: 15-year NPV (2003-2017)
- Emissions – mass and reduction credit values

# Heat to Power Ratio (HPR)


- Crucial parameter for matching energy supply and loads
- Typical average values for two states:
  - NY avg. = 2.3, NY coldest = 7, FL avg. = 1.1, FL hottest = 0.5
- Inherent values for different generation technologies:

– Fuel cell	1.4
– Diesel ICE	1.6
– Gas ICE	2.1
– Gas Turbine	2.0
– Micro Turbine	2.6
- ICE exhaust temperatures sometimes too low to drive absorption chillers


# Data – Energy Demand (1)




## Data – Energy Demand (2)



## Data – Energy Demand (3)



# Data – HPR



- Peak heating demand sets system size



# Simulation

- Excel/Visual Basic
- Set input parameters (demand growth, capital and fuel costs, equipment specifications)
- Set operating strategy
  - Native Baseload
  - Native Steam and/or Electricity Demand
  - Full Capacity
- Meet hourly demand (8760 x 15)
- Calculate NPV, fuel consumption, emissions

# Baseline Costs

- Current prices:
  - Gas ~\$6/Mcf,
  - Electricity ~7¢/kWh with a \$10/kW demand charge
  - Steam ~\$8/Mcf
- FY 2001 CMU energy bill = \$8.4Million
  - NPV = \$100M - \$200M (depends mostly on power price)
  - model assumptions (3% growth,  $r = 2.5\%$ ,  $n = 15$  years)
- Demand charge for 13MW peak (avg.) = \$130,000/mo.
  - NPV = \$24 Million (included in energy bill above)


# Initial Results

- Two baseline systems
  - Current system: coal heat + grid electricity
  - Gas heat system: gas heat + grid electricity (similar to coal + grid w/ wind power purchase)
- System
  - 2 x 7.5MW Solar Turbine “Taurus” gas turbines
  - 1 x supplemental gas boiler
- Operating Strategies
  - 1) CHP, Native Steam and Power
  - 2) CHCP, Native Steam and Power
  - 3) CHCP, Full Capacity

# Limitations


- Emissions
- Demand charge reduction and backup charge
- Part-load performance
- Double-effect absorption chiller
- Deterministic
  - Gas price
  - Power price
  - Allowance prices

# NPV 1




# NPV 2

## 15MW CHCP - Native Power and Steam Loads



# NPV 3



## Fuel Consumption (GJ)

	Gas	Coal	Other (nuke/hydro)	Total
Coal heat, grid electricity	13,000	850,000	210,000	1,100,000
Gas heat, grid electricity	340,000	520,000	210,000	1,100,000
CHP – native load	920,000	-66,000	-27,000	830,000 (78%)
CH <u>C</u> P – native load	910,000	-93,000	-37,000	780,000 (73%)
CH <u>C</u> P – full capacity	1,400,000	-400,00	-160,000	830,000 (77%)

- Negative values are energy not consumed due to power export



# CO<sub>2</sub> emissions

	Emissions (ktons CO <sub>2</sub> )	Change, Coal Baseline (Gas Heat or Grid w/Wind)	Annual Credit Revenue (\$10/ton CO <sub>2</sub> , Coal baseline)	NPV (n=15, r=2.5%)
Coal heat + grid electricity	240			
Gas heat + grid electricity (or coal + grid w/wind)	210	-12% (0%)	\$140,000	\$16M
1 - CHP native load	81	-66% (-61%)	\$780,000	\$12M
2 - CHCP native load	71	-70% (-66%)	\$830,000	\$12M
3 - CHCP full capacity	23	-90% (-89%)	\$1,100,000	\$2M

- Onsite generation backs out baseload coal
- Wind purchase about -4% CO<sub>2</sub> emissions, NPV about -\$1M

## Some practical concerns

- Bellefield partners (Pitt, UPMC, Phipps, etc.)
- Current legal structure, management, and labor force
- Duquesne Light Company interest/cooperativeness
- Value of grid support or reliability
- Capital requirements
- Modularity/advanced energy conversion
- Building As Power Plant integration (i.e. remote DG-CHP)



# Fuel Consumption (GJ)

		Gas	Coal	Other (nuke/hydro)	Total
Coal heat and grid electricity	Onsite	13,000	323,000	0	
	Offsite	0	523,000	210,000	
	<b>Net</b>	<b>13,000</b>	<b>850,000</b>	<b>210,000</b>	<b>1,100,000</b>
Gas heat and grid electricity	Onsite	13,000	0	0	
	Offsite	323,000	520,000	210,000	
	<b>Net</b>	<b>340,000</b>	<b>520,000</b>	<b>210,000</b>	<b>1,100,000</b>
CHP native load	Onsite	920,000	0	0	
	Offsite	0	-66,000	-66,000	
	<b>Net</b>	<b>920,000</b>	<b>-66,000</b>	<b>-27,000</b>	<b>830,000 (78%)</b>
CHCP native load	Onsite	910,000	0	0	
	Offsite	0	-66,000	66,000	
	<b>Net</b>	<b>910,000</b>	<b>-93,000</b>	<b>37,000</b>	<b>780,000 (73%)</b>
CHCP full capacity	Onsite	1,400,000	0	0	
	Offsite	0	-66,000	-66,000	
	<b>Net</b>	<b>1,400,000</b>	<b>-400,000</b>	<b>-160,000</b>	<b>830,000 (77%)</b>

- Negative values are energy not consumed due to power export