

# Assessments of CO<sub>2</sub> Capture and Storage for Fossil Fuel Power Plants

Edward S. Rubin

Department of Engineering and Public Policy  
Carnegie Mellon University  
Pittsburgh, Pennsylvania

Carnegie Mellon Electricity Industry Center Seminar  
Pittsburgh, Pennsylvania

October 28, 2004


# Background

- Global climate change induced by human activity has been widely recognized as a major environmental threat now facing the world
- The source of the problem is the accumulation in the atmosphere of “greenhouse gases” – mainly carbon dioxide (CO<sub>2</sub>) from the combustion of the carbon-laden fossil fuels (oil, coal and gas) that supply most of the world’s energy needs
- To address the problem, the 1992 U.N. Framework Convention on Climate Change calls for “**stabilization of greenhouse gas concentrations** in the atmospheric at a level that would prevent dangerous anthropogenic interference with the climate system”

# Stabilization Will Require Large Reductions in CO<sub>2</sub> Emissions

(a) CO<sub>2</sub> Emission Scenarios

(b) Resulting Atmospheric Concentration



Source: IPCC, 2001

*Large emission reductions are needed,  
no matter what target is selected for stabilization!*

# What Options Are Available to Reduce CO<sub>2</sub> Emissions?

- Improve energy efficiency
- Switch to lower-carbon fuels
- Switch to zero-carbon fuels
- Capture and sequester the CO<sub>2</sub> emitted by major point sources (primarily electric power plants)

# Objectives of This Study

- Compare the performance and cost of **current** fossil fuel power systems with and without CO<sub>2</sub> capture and storage (CCS)
  - Pulverized coal combustion (PC)
  - Integrated coal gasification combined cycle (IGCC)
  - Natural gas combined cycle (NGCC)
- Characterize and quantify the major **resource requirements** and **multi-media environmental emissions** associated with these systems

# *The Technologies*

# PC Plant w/ CO<sub>2</sub> Capture & Storage

IEA Case Study\*

**Configure Plant**      Set Parameters      Get Results

**Combustion Controls**

Fuel Type: Coal

NOx Control: None

**Post-Combustion Controls**

NOx Control: Hot-Side SCR

Particulates: Cold-Side ESP

SO<sub>2</sub> Control: Wet FGD

Mercury: None

CO<sub>2</sub> Capture: Amine System


**Solids Management**

Disposal: mixed w/ Landfill

**Plant Diagram**


The diagram illustrates the flow of materials and energy through the plant. It starts with a boiler (red) that produces steam (indicated by a black chimney) and feeds into a hot-side SCR (green). The gas then passes through a cold-side ESP (pink), followed by a wet FGD (blue), and finally an amine system (red) for CO<sub>2</sub> capture. The captured CO<sub>2</sub> is then stored (green). The plant also has a chimney (black) and a stack (green). The diagram shows the flow of materials and energy through the plant, including the boiler, SCR, ESP, FGD, and amine system, leading to CO<sub>2</sub> capture and storage.

# NGCC Plant w/ CO<sub>2</sub> Capture & Storage





# IGCC Plant w/ CO<sub>2</sub> Capture & Storage



# *Comparative Cost Analyses*

# Summary of Recent Studies of CO<sub>2</sub> Capture Cost


*(Includes compression, but excludes transport and storage costs)*

Cost and Performance Measures	PC Plant		IGCC Plant		NGCC Plant	
	Range low-high	Rep. value	Range low-high	Rep. value	Range low-high	Rep. value
Ref. plant emissions (kg CO <sub>2</sub> /MWh)	722-941	795	682-846	757	344-364	358
Percent CO <sub>2</sub> reduction per MWh (%)	80-93	85	81-91	85	83-88	87
Capital cost w/o capture (\$/kW)	1100-1490	1260	1170-1590	1380	447-690	560
Capital cost with capture (\$/kW)	1940-2580	2210	1410-2380	1880	820-2020	1190
Percent increase in capital cost (%)	67-87	77	19-66	36	37-190	110
COE w/o capture (\$/MWh)	37-52	45	41-58	48	22-35	31
COE with capture (\$/MWh)	64-87	77	54-81	65	32-58	46
Percent increase in COE w/capture (%)	61-84	73	20-55	35	32-69	48
Cost of CO <sub>2</sub> avoided (\$/t CO <sub>2</sub> )	42-55	47	13-37	26	35-74	47

*Natural gas prices = \$2-3/GJ; coal prices approx. \$1.2/GJ. IGCC data are for bituminous coals only. Other assumptions vary across studies.*

# Recent CO<sub>2</sub> Capture Cost Estimates

(includes compression, but excludes transport & storage costs)




Natural gas cost = \$2-3/GJ; coal cost approx. \$1.2/GJ. IGCC data for bituminous coals only. Other assumptions vary.  
E.S. Rubin, Carnegie Mellon / CEIC

# What's New Here?

- For cost comparisons, we explore a broader range of assumptions/conditions that influence the cost of these technologies (with and without capture)
- We include CO<sub>2</sub> transport and storage costs
- We highlight the implications of CCS energy requirements on plant-level resource consumption and ancillary environmental impacts
- We use the (publicly available) IECM computer model (Version 4.0.4) to evaluate all three systems

# The IECM is Available At . . .

- **Free Web Download :**
  - [www.iecm-online.com](http://www.iecm-online.com)
- **Technical Support:**
  - [PED.modeling@netl.doe.gov](mailto:PED.modeling@netl.doe.gov)
- **Other Inquires:**
  - [mikeb@cmu.edu](mailto:mikeb@cmu.edu)
  - [rubin@cmu.edu](mailto:rubin@cmu.edu)



*Results for Baseline  
Case Study Assumptions*


# Baseline Assumptions

Parameter	PC	IGCC	NGCC
<b>Reference Plant</b> (~500 MW)	Supercritical	Texaco quench	2 x 7FA
Fuel Type	2%S Bit	2%S Bit	Nat. Gas
Net HHV Efficiency (%)	39.5	37.5	50.3
Capacity Factor (%)	<b>75</b>	<b>75</b>	<b>75</b>
Fuel Cost, HHV (\$/GJ)	<b>1.2</b>	<b>1.2</b>	<b>4.0</b>
<b>CCS Plant</b> (~500 MW <sub>net</sub> )			
CO <sub>2</sub> Capture System	Amine	Shift+Selexol	Amine
CO <sub>2</sub> Removal (%)	90	90	90
Pipeline Pressure (MPa)	13.8	13.8	13.8
Geologic Storage Option	Aquifer	Aquifer	Aquifer


*Also: fixed charge factor = 0.148; all costs in constant 2002 US\$*




# CO<sub>2</sub> Emission Rates (kg/MWh)



# Cost of Electricity (COE) (Levelized \$/MWh)



# Cost of CO<sub>2</sub> Avoided (\$/tonne CO<sub>2</sub>)



# *Effects of Fuel Price and Plant Dispatch*


# Differences in Total Variable Operating Cost w/o CCS (\$/MWh)

(Includes fuel, chemicals, utilities, wastes and byproducts)

Plant	Fuel Price	Ref. Plant
PC	\$1.2/ GJ	(Base case)
IGCC	\$1.2/ GJ	~ 0
NGCC	\$2.2/ GJ	+ 3
	\$4.0/ GJ	+16
	\$5.8/ GJ	+29


**Implication:** *Decreasing dispatch of NGCC at higher gas prices if coal plants are available*

# Recent Trends for NGCC Plants Confirm Gas Price Effect on CF



# Cost of Electricity, Revisited

(Levelized \$/MWh)



# Differences in Total Variable Operating Cost w/ CCS (\$/MWh)


(Includes fuel, chemicals, utilities, wastes and byproducts)

Plant	Fuel Price	CCS Plant
PC	\$1.2/ GJ	(Base case)
IGCC	\$1.2/ GJ	- 9
NGCC	\$2.2/ GJ	- 7
	\$4.0/ GJ	+ 8
	\$5.8/ GJ	+24

**Implication:** *Increasing dispatch of IGCC, and less use of NGCC, when CCS is added*



# Cost of Electricity (\$/MWh) w/ Differential Capacity Factors



*Effects of IGCC*  
*Financing & Operation*


# IGCC — Can You Build It?

- Today, IGCC plants are generally more expensive than conventional PC plants, based on expected COE
- IGCC technology is also perceived as “riskier” by the financial community, and by many utility companies
- Several efforts underway to develop more attractive financing and ownership arrangements to facilitate deployment of IGCC in the U.S. power market

# Two New Scenarios for IGCC Financing and Operation

- *Unfavorable*
  - Higher fixed charge rate of 17.3%  
(20% risk premium on rates of return)
  - Lower plant utilization (CF=65%)
- *Favorable*
  - Lower fixed charge rate of 10.4%  
(e.g., Harvard 3-Party Covenant)
  - Higher plant utilization (CF=85%)

# Cost of Electricity (\$/MWh) for Two New IGCC Scenarios



# Conclusions from Case Studies (1)

- Many factors affect the costs of fossil fuel power plants, with and without CCS; the **variability** of such factors accounts for most differences in published cost estimates
- The recent literature has not adequately characterized realistic ranges and interdependencies of key factors that affect cost comparisons; consideration of such factors can significantly alter the “conventional wisdom” regarding the relative costs of alternative systems
- Buyer beware! Caution and caveats needed when using results of CCS cost studies!

*CCS Energy Penalty Impacts  
on Resource Consumption and  
Multi-media Emissions*

# Energy Penalty Defined

- Commonly defined as the reduction in plant output for a constant fuel input (i.e., the plant derating) due to the CCS system
- On this basis, the case study plant energy penalties are:
  - PC = 24%
  - IGCC = 14%
  - NGCC = 15%



# An Alternative Definition

- Arguably, a more meaningful definition of the CCS energy requirement is the *increase in energy input per unit of product output*
- This measure directly affects the increased resource requirements and environmental emissions per unit of product:
  - Plant fuel consumption
  - Other resource requirements
  - Solid and liquid wastes
  - Air pollutants not captured by CCS
  - Upstream (life cycle) impacts




# CCS Energy Penalty—Redefined

- Increased energy input (EP) determined by change in net plant efficiency ( $\eta$ ) relative to a reference plant without CCS:



$$EP = (\eta_{\text{ref}} / \eta_{\text{CCS}}) - 1$$

- On this basis, energy penalty for case study plants:
  - PC = 31 %; IGCC = 16%; NGCC = 18%
- *Following slides show some of the implications of CCS energy requirements for the case study plant*




# Case Study Increases in Fuel and Reagent Consumption



# Case Study Increases in Solid Wastes & Plant Byproducts



# Case Study Increases in Air Emission Rates



# Conclusions from Case Studies (2)

---

- Current CO<sub>2</sub> capture systems can significantly exacerbate the multi-media environmental impacts and resources required to produce useful products (like electricity)
- Minimizing CCS energy requirements is essential for minimizing these adverse ancillary impacts

# The Critical Importance of Technology Innovation

- New or improved technologies for power generation and CO<sub>2</sub> capture can lower the cost of CCS, *and* significantly reduce adverse secondary impacts by:
  - Improving overall plant efficiency
  - Reducing CCS energy requirements
  - Maximizing co-capture of other pollutants

# Work in Progress at CMU

- *Incorporate performance and cost models of advanced power systems and CO<sub>2</sub> capture options:*
  - Oxyfuel combustion
  - ITM oxygen production
  - Advanced IGCC designs
  - Advanced NGCC
- *Expand and regionalize transport & storage models*
- *Comparative analyses of CO<sub>2</sub> capture options for new and existing power plants*
  - Advanced PC, NGCC and IGCC systems
  - Repowering or rebuild of existing units
- *Assessments of R&D Benefits*