

Cost and Performance Baseline for Fossil Energy Plants



CMU Seminar

September 26, 2007

Julianne Klara, National Energy Technology Laboratory



Fossil Energy Plant Baseline Study

-Report Contains-


Subcritical PC

Supercritical PC

IGCC

NGCC


- Consistent design requirements
- Up-to-date performance and capital cost estimates
- Technologies built now and deployed by 2010



Technical Approach

1. Extensive Process Simulation (ASPEN)

- All major chemical processes and equipment are simulated
- Detailed mass and energy balances
- Performance calculations (auxiliary power, gross/net power output)



2. Cost Estimation

- Inputs from process simulation (Flow Rates/Gas Composition/Pressure/Temp.)
- Sources for cost estimation
 - Parsons
 - Vendor sources where available
- Follow DOE Analysis Guidelines

Study Matrix

Plant Type	ST Cond. (psig/°F/°F)	GT	Gasifier/Boiler	Acid Gas Removal/CO ₂ Separation / Sulfur Recovery	CO ₂ Cap
IGCC	1800/1050/1050 (non-CO ₂ capture cases)	F Class	GE	Selexol / - / Claus	
				Selexol / Selexol / Claus	90%
	CoP E-Gas		MDEA / - / Claus		
			Selexol / Selexol / Claus	88% ¹	
	1800/1000/1000 (CO ₂ capture cases)		Shell	Sulfinol-M / - / Claus	
				Selexol / Selexol / Claus	90%
PC	2400/1050/1050		Subcritical	Wet FGD / - / Gypsum	
				Wet FGD / Econamine / Gypsum	90%
	3500/1100/1100		Supercritical	Wet FGD / - / Gypsum	
				Wet FGD / Econamine / Gypsum	90%
NGCC	2400/1050/950	F Class	HRSG		
				- / Econamine / -	90%

¹ CO₂ capture is limited to 88% by syngas CH₄ content

GEE – GE Energy
CoP – Conoco Phillips



Design Basis: Coal Type

Illinois #6 Coal Ultimate Analysis (weight %)

	As Rec'd	Dry
Moisture	11.12	0
Carbon	63.75	71.72
Hydrogen	4.50	5.06
Nitrogen	1.25	1.41
Chlorine	0.29	0.33
Sulfur	2.51	2.82
Ash	9.70	10.91
Oxygen (by difference)	6.88	7.75
	100.0	100.0
HHV (Btu/lb)	11,666	13,126



Environmental Targets

Pollutant	IGCC ¹	PC ²	NGCC ³
SO ₂	0.0128 lb/MMBtu	0.085 lb/MMBtu	< 0.6 gr S /100 scf
NO _x	15 ppmv (dry) @ 15% O ₂	0.07 lb/MMBtu	2.5 ppmv @ 15% O ₂
PM	0.0071 lb/MMBtu	0.017 lb/MMBtu	Negligible
Hg	> 90% capture	1.14 lb/TBtu	Negligible

¹ Based on EPRI's CoalFleet User Design Basis Specification for Coal-Based IGCC Power Plants

² Based on BACT analysis, exceeding new NSPS requirements

³ Based on EPA pipeline natural gas specification and 40 CFR Part 60, Subpart KKKK



Economic Assumptions

Startup	2010
Plant Life (Years)	20
Capital Charge Factor, %	
High Risk	
(All IGCC, PC/NGCC with CO₂ capture)	17.5
Low Risk	
(PC/NGCC without CO₂ capture)	16.4
Dollars (Constant)	2007
Coal (\$/MM Btu)	1.80
Natural Gas (\$/MM Btu)	6.75
Capacity Factor	
IGCC	80
PC/NGCC	85



Total Plant Cost

- **Includes**

- Equipment
 - Initial chemicals and catalyst loadings
- Materials
- Labor
 - Direct and Indirect
- Engineering and Construction Management
- Project and Process Contingencies

- **Excludes**

- Owner's costs
 - Land, licensing and permitting, AFUDC
- Escalation to period of performance
- Taxes (except payroll)
- Site specific considerations
- Labor incentives in excess of 5 day/10 hour work week
- EPC premiums



Costs do not include “Risk Wrap”

- **Contract approach assumed for study**
 - EPCM (engineering, procurement, construction management)
 - Owner has control of project
 - Risk is reduced with time as scope definition improves by time of contract award
- **as opposed to.....**
 - EPC (engineer, procure, construct)
 - Lump sum contract where contractor assumes all risk for performance, schedule, and cost
 - If willing to accept risk, premiums applied can raise costs dramatically




Power Plant Configurations

Current State-of-the-Art



Current Technology

IGCC Power Plant



Process Design Assumptions:

Dual Train: 2 gasifiers, 2 Comb. Turbine, 1 Steam Turbine

Oxygen: 95% O₂ via Cryogenic ASU, ~4-7% Air Extraction from combustion turbine


Turbines: Advanced F-Class Turbine - 232MWe
N₂ dilution employed to full extent in all cases
Humidification/steam injection used only when necessary to meet syngas specification of ~120 Btu/scf LHV

Steam: 1800psig/1050°F/1050°F




Pre-Combustion Current Technology

IGCC Power Plant with CO₂ Scrubbing



Post-Combustion Current Technology

Pulverized Coal Power Plant with CO₂ Scrubbing



Process Design Assumptions:

Steam:

Subcritical → 2400psig/1050°F/1050°F
 Supercritical → 3500psig/1100°F/1100°F

CO₂ Capture Challenges:

1. Dilute Flue Gas (10-14% CO₂)
2. Low Pressure CO₂
3. 1.5 Million scfm
4. 17,000 ton CO₂/day removed
5. Large Parasitic Loads (Steam + CO₂ Compression)


**Orange Blocks Indicate Unit Operations Added for CO₂ Capture Case*



Current Technology

Natural Gas Combined Cycle*

*Orange Blocks Indicate Unit Operations Added for CO₂ Capture Case



NO_x Control: LNB + SCR to maintain 2.5 ppmvd @ 15% O₂

Steam Conditions: 2400 psig/1050°F/950°F



IGCC Power Plant Cost and Performance

No CO₂ capture



IGCC Performance Results

No CO₂ Capture

	GE Energy	E-Gas	Shell
Gross Power (MW)	770	742	748
Auxiliary Power (MW)			
Base Plant Load	23	25	21
Air Separation Unit	103	91	90
Gas Cleanup	4	3	1
Total Aux. Power (MW)	130	119	112
Net Power (MW)	640	623	636
Heat Rate (Btu/kWh)	8,922	8,681	8,304
Efficiency (HHV)	38.2	39.3	41.1



IGCC Economic Results

No CO₂ Capture

	GE Energy	E-Gas	Shell
Plant Cost (\$/kWe)¹			
Base Plant	1,323	1,272	1,522
Air Separation Unit	287	264	256
Gas Cleanup	203	197	199
Total Plant Cost (\$/kWe)	1,813	1,733	1,977
Capital COE (¢/kWh)			
Capital COE (¢/kWh)	4.53	4.33	4.94
Variable COE (¢/kWh)			
Variable COE (¢/kWh)	3.27	3.20	3.11
Total COE² (¢/kWh)			
Total COE ² (¢/kWh)	7.80	7.53	8.05

¹Total Plant Capital Cost (Includes contingencies and engineering fees)

²January 2007 Dollars, 80% Capacity Factor, 17.5% Capital Charge Factor, Coal cost \$1.80/10⁶Btu



IGCC Power Plant Cost and Performance With CO₂ Capture



Impact of Adding CCS

	GE Energy	
CO ₂ Capture	NO	YES
Gross Power (MW)	770	745
Auxiliary Power (MW)		
Base Plant Load	23	23
Air Separation Unit	103	121
Gas Cleanup/CO ₂ Capture	4	18
CO ₂ Compression	-	27
Total Aux. Power (MW)	130	189
Net Power (MW)	640	556
Heat Rate (Btu/kWh)	8,922	10,505
Efficiency (HHV)	38.2	32.5
Energy Penalty ¹	-	5.7

Steam for WGS and Selexol

↑ in ASU air comp. load w/o CT integration


Includes H₂S/CO₂ Removal in Selexol Solvent

↑ in auxiliary load for compression to 2200 psig

¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture



Impact of CCS on IGCC Capital Cost




CCS = Carbon capture and sequestration

CCS increases TPC by about 35 percent (or ~ \$660/kW)



Impact of CCS on IGCC Efficiency




CCS = Carbon capture and sequestration

Average energy penalty for CCS is 7 percentage points



Impact of CCS on IGCC Cost of Electricity



CCS = Carbon capture and sequestration



PC Power Plant Cost and Performance



Pulverized Coal Performance Summary

	Subcritical		Supercritical	
Coal Flow Rate	5,252	7,759	4,935	7,039
CO ₂ Captured (Ton/day)	0	16,566	0	15,029
Gross Power (MW)	584	681	580	664
Auxiliary Power (MW)				
Base Plant Load	19	36	21	32
Forced + Induced Draft Fans	10	14	9	13
Flue Gas Cleanup	4	5	3	5
CO ₂ Capture	-	24	-	21
CO ₂ Compression	-	52	-	47
Total Aux. Power (MW)	33	131	30	118
Net Power (MW)	550	550	550	546
Efficiency (%HHV)	36.8	25.0	39.1	27.2
Energy Penalty (% Points)	-	11.8	-	11.9

CO₂ Capture decreases net efficiency by ~12 percentage points



Subcritical PC Performance

	Subcritical	
Coal Flow Rate	5,252	7,759
CO ₂ Captured (Ton/day)	0	16,566
Gross Power (MW)	584	681
Auxiliary Power (MW)		
Base Plant Load	19	36
Forced + Induced Draft Fans	10	14
Flue Gas Cleanup	4	5
CO ₂ Capture	-	24
CO ₂ Compression	-	52
Total Aux. Power (MW)	33	131
Net Power (MW)	550	550
Efficiency (%HHV)	36.8	25.0
Energy Penalty (% Points)	-	11.8

48% Increase in Coal Flow Rate

Larger Base Plant

MEA Scrubbing

~17,000 TPD to 2,200 Psig



Pulverized Coal Economic Results

	Subcritical		Supercritical	
CO ₂ Capture	NO	YES	NO	YES
Plant Cost (\$/kWe)¹				
Base Plant	1,302	1,689	1,345	1,729
Gas Cleanup (SOx/NOx)	246	323	229	302
CO ₂ Capture	-	792	-	752
CO ₂ Compression	-	89	-	85
Total Plant Cost (\$/kWe)	1,549	2,895	1,575	2,870
PC CO₂ capture results in:				
Capital COE (¢/kWh)	3.41	Increase in Capital Cost (TPC) ~ \$1,325/kW		
Variable COE (¢/kWh)	2.99	Increase in COE ~5 cents/kWh (~ 183%)		
CO ₂ TS&M COE (¢/kWh)	0.00	0.43	0.00	0.39
Total COE² (¢/kWh)	6.40	11.88	6.33	11.48
Increase in COE (%)	-	85	-	81
\$/tonne CO ₂ Avoided	-	75	-	75

¹Total Plant Capital Cost (Includes contingencies and engineering fees)

²January 2007 Dollars, 85% Capacity Factor, 16.4% (no capture) 17.5% (capture) Capital Charge Factor, Coal cost \$1.80/10⁶Btu, Natural Gas cost \$6.75/10⁶Btu




Technology Comparison

IGCC, PC and NGCC




Net Plant Efficiency



CCS = Carbon capture and sequestration



Total Plant Cost




Total Plant Capital Cost includes contingencies and engineering fees

CCS = Carbon capture and sequestration



Cost of Electricity

LCOE by Cost Component




January 2007 Dollars, Coal cost \$1.80/10⁶Btu, Gas cost \$6.75/10⁶Btu

CCS = Carbon capture and sequestration


TS&M = transport, storage, and monitoring




CO₂ Mitigation Costs



Criteria Pollutant Emissions for All Cases



Raw Water Usage per MW_{net} (Absolute)



Result Highlights

- **Coal-based plants using today's technology are efficient and clean**
- **20 year levelized COE: PC lowest cost generator**
 - IGCC total plant cost ~20% higher than PC
- **With CCS: IGCC lowest coal-based option for CCS**
 - PC TPC > IGCC TPC
 - PC efficiency < IGCC efficiency
- **LCOE* equal when natural gas price is:**
 - No Capture IGCC: \$7.99/MMBtu PC: \$6.15/MMBtu
 - With Capture IGCC: \$7.73/MMBtu PC: \$8.87/MMBtu

* At baseline coal cost of \$1.80/MMBtu



NETL Viewpoint

- **Improved efficiencies and reduced costs are required to improve competitiveness of advanced coal-based systems**
 - In today's market and regulatory environment
 - Also in a carbon constrained scenario
- **Opportunities for Fossil Energy RD&D**
 - Improve performance and cost of clean coal power systems including development of new approaches to capture and sequester greenhouse gases



Thank You!!

Report, Desk Reference & Slides Available

<http://www.netl.doe.gov/technologies/coalpower/refshelf.html>

“Cost and Performance Baseline of Fossil Energy Plants,” DOE/NETL-2007/1281, May 2007.

“Fossil Energy Power Plant Desk Reference” DOE/NETL-2007/1282, May 2007.



Backup Slides




Removal Cost versus Avoided Cost

- **\$/tonne of CO2 captured (removed)**
 - Function of the bulk quantity of CO2 removed from the capture power plant and the increase in COE required for capture
 - Difference in COE divided by **amount of CO2 captured** in the capture plant
- **\$/tonne of CO2 avoided (mitigation cost)**
 - Accounts for the extra energy (auxiliary power) spent to capture CO2, which increases total CO2 per net MWh
 - Difference in COE divided by **difference in emissions** between reference plant and capture plant




Comparison of CO₂ Removed and Avoided

The amount of CO₂ avoided is always less than the amount of CO₂ captured



GE Energy Radiant




Design: Pressurized, single-stage, downward firing, entrained flow, slurry feed, oxygen blown, slagging, radiant and quench cooling


Note: All gasification performance data estimated by the project team to be representative of GE gasifier



ConocoPhillips E-Gas™



Shell Gasification



Design: Pressurized, single-stage, downward firing, entrained flow, dry feed, oxygen blown, convective cooler

Notes:

1. All gasification performance data estimated by the project team to be representative of Shell gasifier.
2. CO₂ capture incorporates full water quench instead of syngas quench.

Syngas	
350°F, 600 Psia	
Composition (Mole%):	
H ₂	29%
CO	57%
CO ₂	2%
H ₂ O	4%
Other	8%
H ₂ O/CO = 0.1	

To Acid Gas Removal
or
To Shift



Source: "The Shell Gasification Process", Uhde, ThyssenKrupp Technologies

IGCC Performance Results

	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Gross Power (MW)	770	745	742	694	748	693
Auxiliary Power (MW)						
Base Plant Load	23	23	25	26	21	19
Air Separation Unit	103	121	91	109	90	113
Gas Cleanup/CO ₂ Capture	4	18	3	15	1	16
CO ₂ Compression	-	27	-	26	-	28
Total Aux. Power (MW)	130	189	119	176	112	176
Net Power (MW)	640	556	623	518	636	517
Heat Rate (Btu/kWh)	8,922	10,505	8,681	10,757	8,304	10,674
Efficiency (HHV)	38.2	32.5	39.3	31.7	41.1	32.0
Energy Penalty¹	-	5.7	-	7.6	-	9.1

¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture



IGCC Economic Results

	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Plant Cost (\$/kWe)¹						
Base Plant	1,323	1,566	1,272	1,592	1,522	1,817
Air Separation Unit	287	342	264	329	256	336
Gas Cleanup/CO ₂ Capture	203	414	197	441	199	445
CO ₂ Compression	-	68	-	69	-	70
Total Plant Cost (\$/kWe)	1,813	2,390	1,733	2,431	1,977	2,668
Capital COE (¢/kWh)						
Capital COE (¢/kWh)	4.53	5.97	4.33	6.07	4.94	6.66
Variable COE (¢/kWh)						
Variable COE (¢/kWh)	3.27	3.93	3.20	4.09	3.11	3.97
CO₂ TS&M COE (¢/kWh)						
CO ₂ TS&M COE (¢/kWh)	0.00	0.39	0.00	0.41	0.00	0.41
Total COE² (¢/kWh)						
Total COE ² (¢/kWh)	7.80	10.29	7.53	10.57	8.05	11.04
Increase in COE (%)						
Increase in COE (%)	-	32	-	40	-	37
\$/tonne CO₂ Avoided						
\$/tonne CO ₂ Avoided	-	35	-	45	-	46

¹Total Plant Capital Cost (Includes contingencies and engineering fees)

²January 2007 Dollars, 80% Capacity Factor, 17.5% Capital Charge Factor, Coal cost \$1.80/10⁶Btu



PC and NGCC Performance Results

	Subcritical		Supercritical		NGCC	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Gross Power (MW)	583	680	580	663	570	520
Base Plant Load	29	48	26	43	10	13
Gas Cleanup/CO ₂ Capture	4	30	4	27	0	10
CO ₂ Compression	-	52	-	47	0	15
Total Aux. Power (MW)	33	130	30	117	10	38
Net Power (MW)	550	550	550	546	560	482
Heat Rate (Btu/kWh)	9,276	13,724	8,721	12,534	6,719	7,813
Efficiency (HHV)	36.8	24.9	39.1	27.2	50.8	43.7
Energy Penalty ¹	-	11.9	-	11.9	-	7.1

¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture



PC and NGCC Economic Results

	Subcritical		Supercritical		NGCC	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Plant Cost (\$/kWe)¹						
Base Plant	1,302	1,689	1,345	1,729	554	676
Gas Cleanup (SOx/NOx)	246	323	229	302	-	-
CO ₂ Capture	-	792	-	752	-	441
CO ₂ Compression	-	89	-	85	-	52
Total Plant Cost (\$/kWe)	1,549	2,895	1,575	2,870	554	1,172
Capital COE (¢/kWh)						
Capital COE (¢/kWh)	3.41	6.81	3.47	6.75	1.22	2.75
Variable COE (¢/kWh)						
Variable COE (¢/kWh)	2.99	4.64	2.86	4.34	5.62	6.70
CO₂ TS&M COE (¢/kWh)						
CO ₂ TS&M COE (¢/kWh)	0.00	0.43	0.00	0.39	0.00	0.29
Total COE² (¢/kWh)	6.40	11.88	6.33	11.48	6.84	9.74
Increase in COE (%)	-	85	-	81	-	43
\$/tonne CO₂ Avoided	-	75	-	75	-	91

¹Total Plant Capital Cost (Includes contingencies and engineering fees)

²January 2007 Dollars, 85% Capacity Factor, 16.4% (no capture) 17.5% (capture) Capital Charge Factor, Coal cost \$1.80/10⁶Btu, Natural Gas cost \$6.75/10⁶Btu

