Monthly Fire Extinguisher Inspection

- Confirm the extinguisher is visible, unobstructed, and in its designated location.
- Verify the locking pin is intact and the tamper seal is unbroken. Examine the
 extinguisher for obvious physical damage, corrosion, leakage, or clogged
 nozzle.
- Confirm the pressure gauge or indicator is in the operable range or position, and lift the extinguisher to ensure it is still full.
- Check front of tag service date to see if extinguisher was maintained or recharged within the past 12 months.
- Initial and date the back of the Tag.
- Extinguisher condition- If damaged or gauge is in the recharge range immediately contact FMCS and submit work order for fire extinguisher to be serviced.